

Attachment 1: List of Outstanding Shelters that Need Repair

Panel No	ACT Next Bus Location	Sales Address	Area Name	ACT: Power to Shelter?
703341	San Pablo - San Pablo @ Stone SB	San Pablo Ave WS 50ft S/O Stone St F/N - 1	San Pablo	No Power
700891	Berkeley - San Pablo @ Gilman SB	San Pablo Ave WS 75ft S/O Gilman St F/N - 1	Berkeley	No Power
703261	1303600 Richmond - San Pablo Ave. @ McDonald NB L LC 7 72 72R	San Pablo Ave. ES 170ft N/O MacDonald Ave F/S - 1	Richmond	No Power
703271	Richmond - San Pablo Ave @ McDonald SB	San Pablo Ave WS 200ft N/O MacDonald Ave F/N - 1	Richmond	No Power
793051	Newark - Ardenwood Park & Ride 1	Newark Blvd WS 350ft S/O Ardenwood Blvd F/N - 1	Fremont	No Power
703111	University/San Pablo	University Ave NS 48ft E/O San Pablo Ave F/E - 1	Berkeley	Tripped breaker
701331	San Leandro Hospital	E.14th SS 350	San Leandro	No Power